

## **Xtreme<sup>®</sup> Bushfire Test Compliance Certification**

Trend<sup>®</sup> Windows & Doors Pty Ltd has tested the Xtreme<sup>®</sup> range of products consisting of awning, sliding, casement and Crestlite<sup>®</sup> fixedlite windows as well as bifold, hinged, sliding and stacker doors.

CSIRO Test Report - FSZ1373, dated November 2009  
Awning, sliding, casement and Crestlite<sup>®</sup> fixedlite windows, bifold and hinged doors.

CSIRO Test Report - FSZ1372, dated November 2009  
Sliding and stacker doors.

Tested to Australian Standards AS1530.8.1 - 2007, 40kW/m<sup>2</sup> under the requirements of Australian Standard AS3959 - 2009, Section 8.1, BAL-40 Construction of buildings in bushfire prone areas.